



# Updates to NFPA 70B AND WHAT IT MEANS FOR YOU





# Introduction: Adam Dittbenner

- | Instrumentation Service Manager for 18 years
- | Industry experience: oil seed, biodiesel, ethanol, value-added ag
- | Find me at booth 1306 after the presentation

# WHAT'S THE DIFFERENCE?

## NFPA 70

Covers safe installation of electrical wiring and equipment

## NFPA 70E

Addresses worker and electrical safety

## \*NFPA 70B\*

Sets the standard for preventative maintenance of equipment

# What is NFPA 70B?

## What is NFPA 70B?

- | Provides best practices for electrical equipment maintenance
- | Aims to enhance safety and efficiency

## Applicability

- | Applies to industrial facilities
- | Applies to commercial facilities
- | Applies to institutional facilities

## Scope

- | Emphasizes preventative maintenance
  - | Extends equipment lifespan
  - | Reduces downtime
  - | Minimizes hazards
-

# How is this Enforced?

NFPA is enforced by local governments, fire departments, building inspectors, and insurance companies

Nationally, OSHA incorporates NFPA into its standards

A decorative horizontal line in yellow is positioned above a dark blue footer area at the bottom of the slide.

# **UNDERSTANDING NFPA 70B**

# NFPA 70B

In 2023, NEC updated NFPA 70B. Here are three things to keep in mind with this change

- | Changed code from a *recommendation* to a *standard*
- | Recommendations are based on the criticality of the equipment
- | Start planning now for this change

# Topics in NFPA 70B

- | Developing a maintenance program
  - | Detailed equipment procedures
  - | Frequency and types of tests and measurements
  - | Maintaining detailed maintenance records
  - | Ensuring One Lines, Reliability Studies, and Arc-Flash Studies are up to date
-

# Equipment Condition Assessment

(9.3.1.1, 2, and 3)

**Condition 1:** like new, clean, no issues, previous maintenance performed per program

**Condition 2:** had or has issues

**Condition 3:** has missed the last two maintenance cycles, had issues the last two checks, currently has urgent issues

Apply to NFPA 70B Table 9.2.2 to determine how often checks should occur.

# Who Can Perform NFPA 70B Work?

**NFPA 70B work should only be performed by qualified, trained, and authorized personnel.**

- | **Qualified individuals** with the knowledge and skills to maintain electrical equipment safely
- | **Trained on electrical hazards** including shock, arc flash, PPE, and lockout/tagout
- | **Authorized by the employer** to perform the specific task
- | **Competent for the job scope** — inspection, testing, maintenance, or troubleshooting
- | **Compliant with applicable code and site requirements**

# Examples of Visual/General Checks

## Visual Inspections

- | Check for signs of wear
- | Look for corrosion
- | Identify overheating issues

## Tightening Connections

## Cleaning

- | Remove dust
- | Clear debris
- | Ensure optimal performance

## Exercising of Breakers

# LOTO Required

## Power Down – Utilities

- | Load Shedding
- | LOTO
- | Ground Cluster Installation



# Examples of Electrical Testing

## IR Scans (Thermography)

### Transformers


- | Check oil quality

### Cables and Bus Bars

- | Megging vs. DLRO

### Motors

### Grounding and Bonding





# EPM Breaker Testing

With specialized predictive and preventative services, we identify electrical components that are not operating as they should or are nearing failure.

## Why test your breakers?

- | To ensure they will operate properly
- | To ensure they trip at the set point
- | To prevent future down time
- | To fulfill requirements of NFPA 70B
- | Safety- removing energy, limiting human exposure



# Documentation and Record Keeping

EQUIPMNT TYPE	DESCRIPTION	LOCATION	Visual Inspection	Cleaned	Exercised	Comments (Condition as Found)	Recommended Action	Action Taken	Signature	Date
MAIN MCC	FEED FROM UTILITY	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	GH	11/11/2023
MAIN MCC	MCC2 MAIN	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	GH	11/11/2023
MAIN MCC	SPARE BREAKER	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	GH	11/11/2023
MAIN MCC	MCC1 MAIN	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	GH	11/11/2023
MAIN MCC	HP-1	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	GH	11/11/2023
MCC1 FEED FROM SB-1	LADDER GATE (RO2A)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	GH	11/11/2023
MCC1 FEED FROM SB-1	LADDER GATE (RO3A)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	FAN (RO2C)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	FAN (RO3C)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	FAN (RO5C)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	RECEIVING BUCKET ELEVATOR(R05)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	DRAG CONVEYOR (R10)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	R10A VORTEX SPOUT	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	R108 VORTEX SPROUT	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	R10C VORTEX SPROUT	MAIN MCC ROOM	X	X	X	BAD RESET SWITCH	REPLACE RESET SWITCH	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	DRAG CONVEYOR (R11)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	DRAG CONVEYOR VFD (RO4)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	DRAG CONVEYOR (R09)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	ELECTRIC GATE (R09E)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	ELECTRIC GATE (R09A)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	ELECTRIC GATE (R09B)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	ELECTRIC GATE (RO9C)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023
MCC1 FEED FROM SB-1	ELECTRIC GATE (R09D)	MAIN MCC ROOM	X	X	X	ACCEPTABLE	NONE	NONE	BB	11/11/2023

# 6 Year Plan

Task/Activity	Year 1 (2026)	Year 2 (2027)	Year 3 (2028)	Year 4 (2029)	Year 5 (2030)	Year 6 (2031)
Breaker Injection Testing	x					x
Infrared Scanning	x	x	x	x	x	x
Grounding Audit and Testing	x			x		
Switchgear, Panel, and MCC Bucket Cleaning		x		x		x
Arc Flash Assessment	x	x	x (5 Year Audit)	x	x	x
Liquid Filled Transformer Oil check	x	x	x	x	x	x
Remediation and Documentation	x	x	x	x	x	x

# Instrumentation Preventative Maintenance

NIST calibration of critical devices:

- | Pressure
- | Temperature
- | Level
- | Flow
- | Analytical (pH Conductivity)
- | Fixed gas detection
- | Alarm Set Point Verification /  
Shutdown Interlock verification



# Learn More

Scan for the slide deck and additional NFPA 70B resources.



# THANK YOU!

## Connect with Adam Dittbenner



adam.dittbenner@interstates.com



linkedin.com/in/adam-dittbenner-pe-isa-ccst-ii-b0853586/

## Find Interstates at booth 1306

## Connect with Interstates



Interstates



@InterstatesCO



@InterstatesCO

# INTERSTATES

